



525 Union Centre Drive
West Chester, OH 45069
513.860.1800

January 1, 2015

Subject: Certificate of Compliance
Product: THHN Copper

We hereby certify that the materials manufactured by Republic Wire, Inc., enumerated and described herein below, are produced under standard commercial processing and testing methods designed to insure that the finished materials comply with the pertinent standards and/or specifications as indicated.

We further certify that, when these materials are listed under the Label Service Procedures of the Underwriters Laboratories Inc., the materials bear Underwriters' Laboratories label when shipped from the factory.

Republic Wire Type THHN/THWN-2 gauge sizes 18 thru 750 mcm is in accordance with ASTM specification B3 and B8 (stranded where applicable) as well as UL specification 83, NEMA WC70, ICEA S-95-658 and Federal specification JC-30A. In addition to these specifications, Republic Wire type THHN/THWN-2 building wire is in accordance with the sunlight resistance, VW-1, CT USE (1/0 gauge and larger) and CSA Canadian standards for T90. The THHN-2 specification indicates that all wires are rated up to 90 degrees for both wet and dry applications. This material is REACH compliant as well.

All material gauge size 1/0 and larger is coated with a silicone additive which allows for a "no lube" effect on the wire.

The material stated herein is rated for both horizontal and vertical applications.

This letter is to further certify that the described material has been manufactured within the United States and are compliant with Directive 2011/65/EU of the European Parliament and of the Council of 8 June 2011 on the restriction of the use of certain hazardous substances in electrical and electronic equipment (RoHS recast).

Thank You,

Jeremy Rosenbeck
Vice President of Sales
Republic Wire, Inc.